



འབྲུག་གྲོག་མེ་ལས་འཛིན།
Bhutan Power Corporation Limited
(An ISO 9001:2015, ISO 14001:2015 & OHSAS 18001:2007 Certified Company)
(Registered Office, Thimphu)
Distribution and Customer Services Department
Thimphu: Bhutan



61/BPC/DCSD/Load Sanction/2020/330 ,

July 27, 2020

Mr. Tika Ram Katel (Promoter)
Spices Production Plant
Jigmeling Industrial Estate
Sarpang: Bhutan

17611118

Subject: **Issue of Power Clearance**

Dear Sir,

This has reference to your letter No. Nil dated 23rd July 2020 requesting power clearance to set up a spices production plant at Jigmeling Industrial Park, Sarpang. In this regard, BPC is pleased to issue a power clearance of 21 kW for your proposed plant with the following conditions.

1. The applicant has to make its own arrangement for drawing power from the existing BPC infrastructure.
2. The industry should be willing to allow BPC to supply power to other customers from the lines/substation so built by it if BPC so requires in the future.
3. The plant will have to maintain a minimum power factor of 0.85.
4. Once you have acquired the license for your plant, you will have to apply to us for load sanction and fulfill the necessary formalities.

For further information, you are requested to follow up with our Electricity Services Division office in Gelephu.

Thanking you.

Yours sincerely,

(Chador Phuntsho)
General Manager

Copy to:

1. Chief Manager, ESD Gelephu for information and necessary action
2. Senior Manager, EMCCD for information